Curaflam® Rollit

- Penetration sealing of supply/disposal lines using fire protection tape
- For flammable and fire-proof pipes
- Building services: wastewater, drinking water, gas, heating, compressed air, sprinkler, electric







APPLICATION AREAS

- Steel, stainless steel, copper, cast iron $\emptyset \leq 160 \text{ mm}$
- Aluminium $\emptyset \le 32 \text{ mm}$
- Plastic, plastic composite $\emptyset \leq 32 \text{ mm}$

INSTALLATION CONDITIONS

- Secure around duct in component thickness
- Seal the remaining annular gap between the duct and the component with cement mortar, concrete or a material of similar strength

Curaflam® Rollit installed





L-MT-2-907-12,

echnical changes. Some illustrations include accessories.



Detailed information concerning the application areas and provisions for execution can be found in the local LAR.



Curaflam® Rollit

Penetration sealing of flammable and fire-proof supply/disposal lines

In accordance with (M)LAR

Pipe Ø [mm]	Tape length [mm]	Possible number of penetration seals per packaging unit (PU) ${\sf Curaflam}^{\circledast} \ {\sf Rollit} \ {\sf width} = 200 \ {\sf mm}, {\sf thickness} = 4 \ {\sf mm}$	
[]	[]	PU 1.1 m	PU 10 m
≤ 35	160	7	64
≤ 58	230	4	40
≤ 76	290	3	35
≤ 83	310	3	33
≤ 89	330	3	31
≤ 110	400	2	26
≤ 135	470	2	21
≤ 160	550	2	18

Note: calculated reference values without fragmentation and additions. Calculation basis: component thickness ≤ 200 mm.

Curaflam® Rollit Box

Product	Length	Article number
Curaflam® Rollit Box	10 m	3 24 0 000 000 0 2

Scope of delivery: 10 m tape, 200 mm wide, including 30 adhesive strips and 15 fire protection shields, installation instructions.



Curaflam® Rollit Box

Curaflam® Rollit Pack

Product	Length	Article number
Curaflam® Rollit Pack	1,1 m	3 24 0 001 100 0 0

Scope of delivery: 1.10 m tape, 200 mm wide, including 3 fire protection shields, installation instructions.



Curaflam® Rollit Pack